



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

June 03, 2024

Joel Higdon
Creswell School District #40
998 West A Street
Creswell, OR 97426
TEL: (541) 895-6008
FAX:

RE: Elementary

Order No.: 2405480

Dear Joel Higdon:

Analytical Laboratory Group received 18 sample(s) on 5/9/2024 for the analyses presented in the following report.

Kimberly Reever Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 2405480
Date: 6/3/2024

CLIENT: Creswell School District #40
Project: Elementary

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

WO#: 2405480
CLIENT: Creswell School District #40
Project: Elementary
PWS Number:
Sample Source:

Received Date: 5/9/2024 1:53:00 PM
Sampler Name Crystal Erickson
Matrix: Drinking Water
Sample Type:

Lab ID: 2405480-001 **Client Sample ID** CES S Pod Commons **Collection Date:** 5/5/2024 6:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/30/2024 9:12:00 AM	KG

Lab ID: 2405480-002 **Client Sample ID** CES No1 **Collection Date:** 5/5/2024 6:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Lab ID: 2405480-003 **Client Sample ID** CES No2 **Collection Date:** 5/5/2024 6:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Lab ID: 2405480-004 **Client Sample ID** CES No3 **Collection Date:** 5/5/2024 6:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Lab ID: 2405480-005 **Client Sample ID** CES No4 **Collection Date:** 5/5/2024 6:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Lab ID: 2405480-006 **Client Sample ID** CES No5 **Collection Date:** 5/5/2024 6:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Lab ID: 2405480-007 **Client Sample ID** CES No6 **Collection Date:** 5/5/2024 6:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Lab ID: 2405480-008 **Client Sample ID** CES N Pod Commons **Collection Date:** 5/5/2024 6:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

WO#: 2405480
CLIENT: Creswell School District #40
Project: Elementary
PWS Number:
Sample Source:

Received Date: 5/9/2024 1:53:00 PM
Sampler Name Crystal Erickson
Matrix: Drinking Water
Sample Type:

Lab ID: 2405480-009 **Client Sample ID** CES No7 **Collection Date:** 5/5/2024 6:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Lab ID: 2405480-010 **Client Sample ID** CES No8 **Collection Date:** 5/5/2024 6:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Lab ID: 2405480-011 **Client Sample ID** CES No9 **Collection Date:** 5/5/2024 6:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Lab ID: 2405480-012 **Client Sample ID** CES No10 **Collection Date:** 5/5/2024 6:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Lab ID: 2405480-013 **Client Sample ID** CES No11 **Collection Date:** 5/5/2024 6:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Lab ID: 2405480-014 **Client Sample ID** CES No12 **Collection Date:** 5/5/2024 6:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Lab ID: 2405480-015 **Client Sample ID** CES Music Rm **Collection Date:** 5/5/2024 6:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 2405480
CLIENT: Creswell School District #40
Project: Elementary
PWS Number:
Sample Source:

Received Date: 5/9/2024 1:53:00 PM
Sampler Name Crystal Erickson
Matrix: Drinking Water
Sample Type:

Lab ID: 2405480-016 **Client Sample ID** CES Gym Fountain **Collection Date:** 5/5/2024 6:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Lab ID: 2405480-017 **Client Sample ID** CES Fntn Outside Life Skills **Collection Date:** 5/5/2024 6:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Lab ID: 2405480-018 **Client Sample ID** CES Life Skills **Collection Date:** 5/5/2024 6:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Definition Base

WO#: 2405480
Date: 6/3/2024

Definitions:

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- A Accredited by ORELAP
- C Value is below Minimum Compound Limit.
- E Value above quantitation range
- H Holding times for preparation or analysis exceeded
- LOD Limit of Detection
- MCL Maximum Contaminant Level
- NAR See note in Case Narrative
- ND Not Detected at the Reporting Limit
- PL Permit Limit
- PQL Practical Quantitation Level or Reporting Limit
- R RPD outside accepted recovery limits
- U Samples with CalcVal < MDL
- W Sample container temperature was outside of the limits as specified by the method.



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 2405480
 03-Jun-24

Client: Creswell School District #40
Project: Elementary

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2405480-001A	CES S Pod Commons	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2405480-002A	CES No1			Lead	A
	2405480-003A	CES No2			Lead	A
	2405480-004A	CES No3			Lead	A
	2405480-005A	CES No4			Lead	A
	2405480-006A	CES No5			Lead	A
	2405480-007A	CES No6			Lead	A
	2405480-008A	CES N Pod Commons			Lead	A
	2405480-009A	CES No7			Lead	A
	2405480-010A	CES No8			Lead	A
	2405480-011A	CES No9			Lead	A
	2405480-012A	CES No10			Lead	A
	2405480-013A	CES No11			Lead	A
	2405480-014A	CES No12			Lead	A
	2405480-015A	CES Music Rm			Lead	A
	2405480-016A	CES Gym Fountain			Lead	A
	2405480-017A	CES Fntn Outside Life Skills			Lead	A
	2405480-018A	CES Life Skills			Lead	A

ACCRED ORELAP A Accredited



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

June 04, 2024

Joel Higdon
Creswell School District #40
998 West A Street
Creswell, OR 97426
TEL: (541) 895-6008
FAX:

RE: High School

Order No.: 2405482

Dear Joel Higdon:

Analytical Laboratory Group received 18 sample(s) on 5/9/2024 for the analyses presented in the following report.

A handwritten signature in black ink that reads 'Kimberly J. Reever Morghan'.

Kimberly Reever Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 2405482
Date: 6/4/2024

CLIENT: Creswell School District #40
Project: High School

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

WO#: 2405482
CLIENT: Creswell School District #40
Project: High School
PWS Number:
Sample Source:

Received Date: 5/9/2024 1:53:00 PM
Sampler Name Crystal Ericson
Matrix: Drinking Water
Sample Type:

Lab ID: 2405482-001 **Client Sample ID** HS Commons Fountain LG **Collection Date:** 5/5/2024 9:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Lab ID: 2405482-002 **Client Sample ID** HS Commons Fountain Small **Collection Date:** 5/5/2024 9:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Lab ID: 2405482-003 **Client Sample ID** HS Kitchen 1 **Collection Date:** 5/5/2024 9:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/23/2024 9:30:00 PM	KG

Lab ID: 2405482-004 **Client Sample ID** HS Kitchen 2 **Collection Date:** 5/5/2024 9:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/30/2024 9:12:00 AM	KG

Lab ID: 2405482-005 **Client Sample ID** HS Concessions **Collection Date:** 5/5/2024 9:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/30/2024 9:12:00 AM	KG

Lab ID: 2405482-006 **Client Sample ID** HS Faucet Outside Weight Rm **Collection Date:** 5/5/2024 9:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/30/2024 9:12:00 AM	KG

Lab ID: 2405482-007 **Client Sample ID** HS Wrestling Fountain **Collection Date:** 5/5/2024 9:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	65.5	15.0	8.00	*	ppb	5/30/2024 3:40:00 PM	KG

Lab ID: 2405482-008 **Client Sample ID** HS Girls Locker Rm Fountain **Collection Date:** 5/5/2024 9:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	14.3	15.0	2.00		ppb	5/30/2024 3:40:00 PM	KG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

WO#: 2405482
CLIENT: Creswell School District #40
Project: High School
PWS Number:
Sample Source:

Received Date: 5/9/2024 1:53:00 PM
Sampler Name Crystal Ericson
Matrix: Drinking Water
Sample Type:

Lab ID: 2405482-009 **Client Sample ID** HS Gym Fountain **Collection Date:** 5/5/2024 9:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/30/2024 3:40:00 PM	KG

Lab ID: 2405482-010 **Client Sample ID** HS Senior Hall Fountain **Collection Date:** 5/5/2024 9:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/30/2024 3:40:00 PM	KG

Lab ID: 2405482-011 **Client Sample ID** HS Jennys Old Office **Collection Date:** 5/5/2024 9:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	34.8	15.0	4.00	*	ppb	5/30/2024 3:40:00 PM	KG

Lab ID: 2405482-012 **Client Sample ID** HS Nurses Office Fountain **Collection Date:** 5/5/2024 9:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/30/2024 3:40:00 PM	KG

Lab ID: 2405482-013 **Client Sample ID** HS H Hall Fountain **Collection Date:** 5/5/2024 9:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/30/2024 3:40:00 PM	KG

Lab ID: 2405482-014 **Client Sample ID** HS Home Ec 1 **Collection Date:** 5/5/2024 9:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.07	15.0	2.00		ppb	5/30/2024 3:40:00 PM	KG

Lab ID: 2405482-015 **Client Sample ID** HS Home Ec 2 **Collection Date:** 5/5/2024 9:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.02	15.0	2.00		ppb	5/30/2024 3:40:00 PM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 2405482
CLIENT: Creswell School District #40
Project: High School
PWS Number:
Sample Source:

Received Date: 5/9/2024 1:53:00 PM
Sampler Name Crystal Ericson
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID			Collection Date: 5/5/2024 9:30:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.07	15.0	2.00		ppb	6/3/2024 12:00:00 PM	AS

Lab ID:	Client Sample ID			Collection Date: 5/5/2024 9:30:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 12:00:00 PM	AS

Lab ID:	Client Sample ID			Collection Date: 5/5/2024 9:30:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.15	15.0	2.00		ppb	6/3/2024 12:00:00 PM	AS

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2405482

Date: 6/4/2024

Definitions:

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- A Accredited by ORELAP
- C Value is below Minimum Compound Limit.
- E Value above quantitation range
- H Holding times for preparation or analysis exceeded
- LOD Limit of Detection
- MCL Maximum Contaminant Level
- NAR See note in Case Narrative
- ND Not Detected at the Reporting Limit
- PL Permit Limit
- PQL Practical Quantitation Level or Reporting Limit
- R RPD outside accepted recovery limits
- U Samples with CalcVal < MDL
- W Sample container temperature was outside of the limits as specified by the method.



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 2405482
 04-Jun-24

Client: Creswell School District #40
Project: High School

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2405482-001A	HS Commons Fountain LG	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2405482-002A	HS Commons Fountain Small			Lead	A
	2405482-003A	HS Kitchen 1			Lead	A
	2405482-004A	HS Kitchen 2			Lead	A
	2405482-005A	HS Concessions			Lead	A
	2405482-006A	HS Faucet Outside Weight Rm			Lead	A
	2405482-007A	HS Wrestling Fountain			Lead	A
	2405482-008A	HS Girls Locker Rm Fountain			Lead	A
	2405482-009A	HS Gym Fountain			Lead	A
	2405482-010A	HS Senior Hall Fountain			Lead	A
	2405482-011A	HS Jennys Old Office			Lead	A
	2405482-012A	HS Nurses Office Fountain			Lead	A
	2405482-013A	HS H Hall Fountain			Lead	A
	2405482-014A	HS Home Ec 1			Lead	A
	2405482-015A	HS Home Ec 2			Lead	A
	2405482-016A	HS Home Ec 3			Lead	A
	2405482-017A	HS Home Ec 4			Lead	A
	2405482-018A	HS Home Ec 5			Lead	A



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

June 03, 2024

Joel Higdon
Creswell School District #40
998 West A Street
Creswell, OR 97426
TEL: (541) 895-6008
FAX:

RE: High School

Order No.: 2405487

Dear Joel Higdon:

Analytical Laboratory Group received 5 sample(s) on 5/9/2024 for the analyses presented in the following report.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 2405487
Date: 6/3/2024

CLIENT: Creswell School District #40
Project: High School

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

WO#: 2405487
CLIENT: Creswell School District #40
Project: High School
PWS Number:
Sample Source:

Received Date: 5/9/2024 1:53:00 PM
Sampler Name Crystal Ericson
Matrix: Drinking Water
Sample Type:

Lab ID: 2405487-001 **Client Sample ID** HS Faucet Outside Welding Shop **Collection Date:** 5/5/2024 10:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	39.5	15.0	4.00	*	ppb	5/30/2024 9:12:00 AM	KG

Lab ID: 2405487-002 **Client Sample ID** HS Sink Outside Wood Shop **Collection Date:** 5/5/2024 10:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.20	15.0	2.00		ppb	5/30/2024 9:12:00 AM	KG

Lab ID: 2405487-003 **Client Sample ID** HS Green House Fountain **Collection Date:** 5/5/2024 10:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/30/2024 9:12:00 AM	KG

Lab ID: 2405487-004 **Client Sample ID** HS Copy Room Sink **Collection Date:** 5/5/2024 10:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.80	15.0	2.00		ppb	5/30/2024 9:12:00 AM	KG

Lab ID: 2405487-005 **Client Sample ID** HS Bulldog Cafe **Collection Date:** 5/6/2024 5:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	5/30/2024 9:12:00 AM	KG

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2405487

Date: 6/3/2024

Definitions:

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- A Accredited by ORELAP
- C Value is below Minimum Compound Limit.
- E Value above quantitation range
- H Holding times for preparation or analysis exceeded
- LOD Limit of Detection
- MCL Maximum Contaminant Level
- NAR See note in Case Narrative
- ND Not Detected at the Reporting Limit
- PL Permit Limit
- PQL Practical Quantitation Level or Reporting Limit
- R RPD outside accepted recovery limits
- U Samples with CalcVal < MDL
- W Sample container temperature was outside of the limits as specified by the method.



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 2405487
 03-Jun-24

Client: Creswell School District #40
Project: High School

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2405487-001A	HS Faucet Outside Welding Shop	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2405487-002A	HS Sink Outside Wood Shop			Lead	A
	2405487-003A	HS Green House Fountain			Lead	A
	2405487-004A	HS Copy Room			Lead	A
	2405487-005A	HS Bulldog Cafe			Lead	A



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

June 04, 2024

Joel Higdon
Creswell School District #40
998 West A Street
Creswell, OR 97426
TEL: (541) 895-6008
FAX:

RE: Elementary

Order No.: 2405488

Dear Joel Higdon:

Analytical Laboratory Group received 13 sample(s) on 5/9/2024 for the analyses presented in the following report.

Kimberly Reever Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 2405488
Date: 6/4/2024

CLIENT: Creswell School District #40
Project: Elementary

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

WO#: 2405488
CLIENT: Creswell School District #40
Project: Elementary
PWS Number:
Sample Source:

Received Date: 5/9/2024 1:53:00 PM
Sampler Name Crystal Ericson
Matrix: Drinking Water
Sample Type:

Lab ID: 2405488-001 **Client Sample ID** Elementary 21 **Collection Date:** 5/5/2024 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 12:00:00 PM	AS

Lab ID: 2405488-002 **Client Sample ID** Elementary 22 **Collection Date:** 5/5/2024 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 12:00:00 PM	AS

Lab ID: 2405488-003 **Client Sample ID** Elementary 23 **Collection Date:** 5/5/2024 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 12:00:00 PM	AS

Lab ID: 2405488-004 **Client Sample ID** E 24 **Collection Date:** 5/5/2024 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 12:00:00 PM	AS

Lab ID: 2405488-005 **Client Sample ID** E 25 **Collection Date:** 5/5/2024 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 12:00:00 PM	AS

Lab ID: 2405488-006 **Client Sample ID** E 26 **Collection Date:** 5/5/2024 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 12:00:00 PM	AS

Lab ID: 2405488-007 **Client Sample ID** E 27 **Collection Date:** 5/5/2024 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 12:00:00 PM	AS

Lab ID: 2405488-008 **Client Sample ID** E 28 **Collection Date:** 5/5/2024 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 12:00:00 PM	AS

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

WO#: 2405488
CLIENT: Creswell School District #40
Project: Elementary
PWS Number:
Sample Source:

Received Date: 5/9/2024 1:53:00 PM
Sampler Name Crystal Ericson
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID	Collection Date: 5/5/2024 7:00:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 12:00:00 PM	AS

Lab ID:	Client Sample ID	Collection Date: 5/5/2024 7:00:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 12:00:00 PM	AS

Lab ID:	Client Sample ID	Collection Date: 5/5/2024 7:00:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.03	15.0	2.00		ppb	6/3/2024 12:00:00 PM	AS

Lab ID:	Client Sample ID	Collection Date: 5/5/2024 7:00:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 12:00:00 PM	AS

Lab ID:	Client Sample ID	Collection Date: 5/5/2024 7:00:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 4:55:00 PM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

Definition Base

WO#: 2405488
Date: 6/4/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program
Analytes Report
 WO#: 2405488
 04-Jun-24

Client: Creswell School District #40
Project: Elementary

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2405488-001A	Elementary 21	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2405488-002A	Elementary 22			Lead	A
	2405488-003A	Elementary 23			Lead	A
	2405488-004A	E 24			Lead	A
	2405488-005A	E 25			Lead	A
	2405488-006A	E 26			Lead	A
	2405488-007A	E 27			Lead	A
	2405488-008A	E 28			Lead	A
	2405488-009A	E 29			Lead	A
	2405488-010A	Elementary 30			Lead	A
	2405488-011A	Elementary 31			Lead	A
	2405488-012A	Elementary 32			Lead	A
	2405488-013A	Elementary 33			Lead	A



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

June 06, 2024

Joel Higdon
Creswell School District #40
998 West A Street
Creswell, OR 97426
TEL: (541) 895-6008
FAX:

RE: Middle School

Order No.: 2405490

Dear Joel Higdon:

Analytical Laboratory Group received 18 sample(s) on 5/9/2024 for the analyses presented in the following report.

Kimberly Reever Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 2405490
Date: 6/6/2024

CLIENT: Creswell School District #40
Project: Middle School

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

WO#: 2405490
CLIENT: Creswell School District #40
Project: Middle School
PWS Number:
Sample Source:

Received Date: 5/9/2024 1:53:00 PM
Sampler Name Crystal Ericson
Matrix: Drinking Water
Sample Type:

Lab ID: 2405490-001 **Client Sample ID** MS Staff Rm **Collection Date:** 5/5/2024 8:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 8:03:00 PM	AS

Lab ID: 2405490-002 **Client Sample ID** MS Conf Room **Collection Date:** 5/5/2024 8:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 8:03:00 PM	AS

Lab ID: 2405490-003 **Client Sample ID** MS Nurse Office **Collection Date:** 5/5/2024 8:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 8:03:00 PM	AS

Lab ID: 2405490-004 **Client Sample ID** MS Music Rm **Collection Date:** 5/5/2024 8:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 8:03:00 PM	AS

Lab ID: 2405490-005 **Client Sample ID** MS Fountain Back Hall **Collection Date:** 5/5/2024 8:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 8:03:00 PM	AS

Lab ID: 2405490-006 **Client Sample ID** MS Gym RR Fountain **Collection Date:** 5/5/2024 8:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 8:03:00 PM	AS

Lab ID: 2405490-007 **Client Sample ID** MS Kitchen 1 **Collection Date:** 5/5/2024 8:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 8:03:00 PM	AS

Lab ID: 2405490-008 **Client Sample ID** MS Kitchen 2 **Collection Date:** 5/5/2024 8:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 8:03:00 PM	AS

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

WO#: 2405490
CLIENT: Creswell School District #40
Project: Middle School
PWS Number:
Sample Source:

Received Date: 5/9/2024 1:53:00 PM
Sampler Name Crystal Ericson
Matrix: Drinking Water
Sample Type:

Lab ID: 2405490-009 **Client Sample ID** MS Student Store **Collection Date:** 5/5/2024 8:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.91	15.0	2.00		ppb	6/3/2024 8:03:00 PM	AS

Lab ID: 2405490-010 **Client Sample ID** MS Fountain Across Custodial **Collection Date:** 5/5/2024 9:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 8:03:00 PM	AS

Lab ID: 2405490-011 **Client Sample ID** MS Fountain Lower East **Collection Date:** 5/5/2024 9:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 8:03:00 PM	AS

Lab ID: 2405490-012 **Client Sample ID** MS Life Skills **Collection Date:** 5/5/2024 9:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 8:03:00 PM	AS

Lab ID: 2405490-013 **Client Sample ID** MS Fountain Lower West **Collection Date:** 5/5/2024 9:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 8:03:00 PM	AS

Lab ID: 2405490-014 **Client Sample ID** MS No201 **Collection Date:** 5/5/2024 9:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 8:03:00 PM	AS

Lab ID: 2405490-015 **Client Sample ID** MS No202 **Collection Date:** 5/5/2024 9:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 8:03:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 2405490
CLIENT: Creswell School District #40
Project: Middle School
PWS Number:
Sample Source:

Received Date: 5/9/2024 1:53:00 PM
Sampler Name Crystal Ericson
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID	MS No	Collection Date:					
2405490-016	MS No203		5/5/2024 9:00:00 AM					
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 8:03:00 PM	AS

Lab ID:	Client Sample ID	MS No	Collection Date:					
2405490-017	MS No204		5/5/2024 9:00:00 AM					
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/6/2024 10:45:00 AM	AS

Lab ID:	Client Sample ID	MS No	Collection Date:					
2405490-018	MS No701		5/5/2024 9:00:00 AM					
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/6/2024 10:45:00 AM	AS

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

Definition Base

WO#: 2405490
Date: 6/6/2024

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 2405490
 06-Jun-24

Client: Creswell School District #40
Project: Middle School

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2405490-001A	MS Staff Rm	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2405490-002A	MS Conf Room			Lead	A
	2405490-003A	MS Nurse Office			Lead	A
	2405490-004A	MS Music Rm			Lead	A
	2405490-005A	MS Fountain Back Hall			Lead	A
	2405490-006A	MS Gym RR Fountain			Lead	A
	2405490-007A	MS Kitchen 1			Lead	A
	2405490-008A	MS Kitchen 2			Lead	A
	2405490-009A	MS Student Store			Lead	A
	2405490-010A	MS Fountain Across Custodial			Lead	A
	2405490-011A	MS Fountain Lower East			Lead	A
	2405490-012A	MS Life Skills			Lead	A
	2405490-013A	MS Fountain Lower West			Lead	A
	2405490-014A	MS No201			Lead	A
	2405490-015A	MS No202			Lead	A
	2405490-016A	MS No203			Lead	A
	2405490-017A	MS No204			Lead	A
	2405490-018A	MS No701			Lead	A



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

June 04, 2024

Joel Higdon
Creswell School District #40
998 West A Street
Creswell, OR 97426
TEL: (541) 895-6008
FAX:

RE: Middle School

Order No.: 2405493

Dear Joel Higdon:

Analytical Laboratory Group received 9 sample(s) on 5/9/2024 for the analyses presented in the following report.

Kimberly Reever Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 2405493
Date: 6/4/2024

CLIENT: Creswell School District #40
Project: Middle School

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

WO#: 2405493
CLIENT: Creswell School District #40
Project: Middle School
PWS Number:
Sample Source:

Received Date: 5/9/2024 1:53:00 PM
Sampler Name Crystal Ericson
Matrix: Drinking Water
Sample Type:

Lab ID: 2405493-001 **Client Sample ID** MS No702 **Collection Date:** 5/5/2024 9:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 4:55:00 PM	AS

Lab ID: 2405493-002 **Client Sample ID** MS No703 **Collection Date:** 5/5/2024 9:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	7.52	15.0	2.00		ppb	6/3/2024 4:55:00 PM	AS

Lab ID: 2405493-003 **Client Sample ID** MS Upper East Fountain **Collection Date:** 5/5/2024 9:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 4:55:00 PM	AS

Lab ID: 2405493-004 **Client Sample ID** MS Library Copy Room **Collection Date:** 5/5/2024 9:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 4:55:00 PM	AS

Lab ID: 2405493-005 **Client Sample ID** MS Upper West Fountain **Collection Date:** 5/5/2024 9:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 4:55:00 PM	AS

Lab ID: 2405493-006 **Client Sample ID** MS 601 **Collection Date:** 5/5/2024 9:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 4:55:00 PM	AS

Lab ID: 2405493-007 **Client Sample ID** MS 602 **Collection Date:** 5/5/2024 9:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 4:55:00 PM	AS

Lab ID: 2405493-008 **Client Sample ID** MS 603 **Collection Date:** 5/5/2024 9:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 4:55:00 PM	AS

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

WO#: 2405493
CLIENT: Creswell School District #40
Project: Middle School
PWS Number:
Sample Source:

Received Date: 5/9/2024 1:53:00 PM
Sampler Name Crystal Ericson
Matrix: Drinking Water
Sample Type:

Lab ID: 2405493-009	Client Sample ID MS 604	Collection Date: 5/5/2024 9:30:00 AM						
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/3/2024 4:55:00 PM	AS

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2405493

Date: 6/4/2024

Definitions:

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- A Accredited by ORELAP
- C Value is below Minimum Compound Limit.
- E Value above quantitation range
- H Holding times for preparation or analysis exceeded
- LOD Limit of Detection
- MCL Maximum Contaminant Level
- NAR See note in Case Narrative
- ND Not Detected at the Reporting Limit
- PL Permit Limit
- PQL Practical Quantitation Level or Reporting Limit
- R RPD outside accepted recovery limits
- U Samples with CalcVal < MDL
- W Sample container temperature was outside of the limits as specified by the method.



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

**Accreditation Program
 Analytes Report**
 WO#: 2405493
 04-Jun-24

Client: Creswell School District #40
Project: Middle School

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2405493-001A	MS No702	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2405493-002A	MS No703			Lead	A
	2405493-003A	MS Upper East Fountain			Lead	A
	2405493-004A	MS Library Copy Room			Lead	A
	2405493-005A	MS Upper West Fountain			Lead	A
	2405493-006A	MS 601			Lead	A
	2405493-007A	MS 602			Lead	A
	2405493-008A	MS 603			Lead	A
	2405493-009A	MS 604			Lead	A



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

June 07, 2024

Joel Higdon
Creswell School District #40
998 West A Street
Creswell, OR 97426
TEL: (541) 895-6000
FAX:

RE: Elementary

Order No.: 2405494

Dear Joel Higdon:

Analytical Laboratory Group received 17 sample(s) on 5/9/2024 for the analyses presented in the following report.

Kimberly Reever Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 2405494
Date: 6/7/2024

CLIENT: Creswell School District #40
Project: Elementary

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.

WO#: 2405494
CLIENT: Creswell School District #40
Project: Elementary
PWS Number:
Sample Source:

Received Date: 5/9/2024 1:53:00 PM
Sampler Name Crystal Ericson
Matrix: Drinking Water
Sample Type:

Lab ID: 2405494-001 **Client Sample ID** CES Nurses Office **Collection Date:** 5/5/2024 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/6/2024 10:45:00 AM	AS

Lab ID: 2405494-002 **Client Sample ID** CES Counselors Office **Collection Date:** 5/5/2024 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/6/2024 10:45:00 AM	AS

Lab ID: 2405494-003 **Client Sample ID** CES #13 Staff Room **Collection Date:** 5/5/2024 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	6.86	15.0	2.00		ppb	6/6/2024 10:45:00 AM	AS

Lab ID: 2405494-004 **Client Sample ID** CES #14 **Collection Date:** 5/5/2024 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.48	15.0	2.00		ppb	6/6/2024 10:45:00 AM	AS

Lab ID: 2405494-005 **Client Sample ID** CES #15 **Collection Date:** 5/5/2024 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/6/2024 10:45:00 AM	AS

Lab ID: 2405494-006 **Client Sample ID** CES #16 **Collection Date:** 5/5/2024 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	38.5	15.0	4.00	*	ppb	6/6/2024 10:45:00 AM	AS

Lab ID: 2405494-007 **Client Sample ID** CES #17 **Collection Date:** 5/5/2024 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	20.6	15.0	4.00	*	ppb	6/6/2024 10:45:00 AM	AS

Lab ID: 2405494-008 **Client Sample ID** CES #18 **Collection Date:** 5/5/2024 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/6/2024 10:45:00 AM	AS

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

WO#: 2405494
CLIENT: Creswell School District #40
Project: Elementary
PWS Number:
Sample Source:

Received Date: 5/9/2024 1:53:00 PM
Sampler Name Crystal Ericson
Matrix: Drinking Water
Sample Type:

Lab ID: 2405494-009 **Client Sample ID** CES #19 **Collection Date:** 5/5/2024 7:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/6/2024 10:45:00 AM	AS

Lab ID: 2405494-010 **Client Sample ID** CES #20 **Collection Date:** 5/5/2024 7:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/6/2024 10:45:00 AM	AS

Lab ID: 2405494-011 **Client Sample ID** CES Fountain Outside DO **Collection Date:** 5/5/2024 7:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/6/2024 10:45:00 AM	AS

Lab ID: 2405494-012 **Client Sample ID** CES Fountain Inside Cafe **Collection Date:** 5/5/2024 7:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/6/2024 10:45:00 AM	AS

Lab ID: 2405494-013 **Client Sample ID** CES Fountain by Dumpsters **Collection Date:** 5/5/2024 7:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	4.15	15.0	2.00		ppb	6/6/2024 10:45:00 AM	AS

Lab ID: 2405494-014 **Client Sample ID** CES Sink in DO **Collection Date:** 5/5/2024 7:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/6/2024 10:45:00 AM	AS

Lab ID: 2405494-015 **Client Sample ID** CES Kitchen 1 **Collection Date:** 5/5/2024 7:30:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/6/2024 10:45:00 AM	AS

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit

WO#: 2405494
CLIENT: Creswell School District #40
Project: Elementary
PWS Number:
Sample Source:

Received Date: 5/9/2024 1:53:00 PM
Sampler Name Crystal Ericson
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
2405494-016	CES Kitchen 2	ND	15.0	2.00		ppb	6/6/2024 10:45:00 AM	AS

Lab ID:	Client Sample ID	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
2405494-017	CES Kitchen 3	ND	15.0	2.00		ppb	6/6/2024 10:45:00 AM	AS

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)	A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.	E	Value above quantitation range
H	Holding times for preparation or analysis exceeded	LOD	Limit of Detection
MCL	Maximum Contaminant Level	NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit	PL	Permit Limit



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Definition Base

WO#: 2405494
Date: 6/7/2024

Definitions:

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- A Accredited by ORELAP
- C Value is below Minimum Compound Limit.
- E Value above quantitation range
- H Holding times for preparation or analysis exceeded
- LOD Limit of Detection
- MCL Maximum Contaminant Level
- NAR See note in Case Narrative
- ND Not Detected at the Reporting Limit
- PL Permit Limit
- PQL Practical Quantitation Level or Reporting Limit
- R RPD outside accepted recovery limits
- U Samples with CalcVal < MDL
- W Sample container temperature was outside of the limits as specified by the method.



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

**Accreditation Program
 Analytes Report**
 WO#: 2405494
 07-Jun-24

Client: Creswell School District #40
Project: Elementary

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2405494-001A	CES Nurses Office	Drinking Water	AA Metals by SM 3113 Daycare 250mL	Lead	A
	2405494-002A	CES Counselors Office			Lead	A
	2405494-003A	CES #13 Staff Room			Lead	A
	2405494-004A	CES #14			Lead	A
	2405494-005A	CES #15			Lead	A
	2405494-006A	CES #16			Lead	A
	2405494-007A	CES #17			Lead	A
	2405494-008A	CES #18			Lead	A
	2405494-009A	CES #19			Lead	A
	2405494-010A	CES #20			Lead	A
	2405494-011A	CES Fountain Outside DO			Lead	A
	2405494-012A	CES Fountain Inside Cafe			Lead	A
	2405494-013A	CES Fountain by Dumpsters			Lead	A
	2405494-014A	CES Sink in DO			Lead	A
	2405494-015A	CES Kitchen 1			Lead	A
	2405494-016A	CES Kitchen 2			Lead	A
	2405494-017A	CES Kitchen 3			Lead	A